

## Town Of Charlton Well Testing Regulations

<b>PARAMETERS</b>	<b>M.C.L.</b>
Aluminum	0.2 mg/L
Antimony	0.006 mg/L
Arsenic	.010 mg/L
Barium	2.0 mg/L
Beryllium	0.004 mg/L
Cadmium	0.005 mg/L
Chloride	250 mg/L
Chromium	0.1 mg/L
Coliform	Absent
Color	15 C.U.
Copper (action level)	1.3 mg/L
Cyanide	0.20 mg/L
Flouride	2 mg/L
Foaming agents	0.5 mg/L
Gross Alpha	15 pCi/L
Iron	0.3 mg/L
Lead (action level)	0.015 mg/L
Manganese	0.05 mg/L
Mercury	0.002 mg/L
Nickel	0.1 mg/L
Nitrate	10 mg/L
Nitrite	1 mg/L
Odor	3 T.O.N.
PH	6.5-8.5 S.U
Radium 226 & 228	5 pCi/L
Radon	Filter required 10,000 & over
Selenium	0.05 mg/L
Silver	0.10 mg/L
Socium (guideline)	28 mg/L
Sulfate	250 mg/L
TDS	500 mg/L
Thallium	0.002 mg/L
Zinc	5 mg/L