

Chapter 140

FIRE PREVENTION

[HISTORY: Adopted by the Town Meeting of the Town of Charlton as indicated in article histories. Amendments noted where applicable.]

ARTICLE I

Fire Hydrants

[Adopted as Art. XVI of the 2005 Bylaws]

§ 140-1. Color of hydrants fed by municipal water lines.

All fire hydrants within the Town of Charlton that are fed by a municipal water line will be red in color and with the bonnet of said hydrant to be painted to adhere to the National Fire Protection Association (N.F.P.A.) (291 2-1, 2-2) color code marking for water flow.

§ 140-2. Color of hydrants fed by private water lines.

All fire hydrants within the Town of Charlton that are fed by a private water line will be yellow in color and with the bonnet of said hydrant to be painted to adhere to the National Fire Protection Association (N.F.P.A.) (291 2-1, 2-2) color code marking for water flow.

§ 140-3. Color of decorative hydrants.

All decorative fire hydrants within the Town of Charlton will be blue in color.

§ 140-4. Color code marking for water flow.

The N.F.P.A. color code system:

Size (gallons per minute)	Color
1,500 or greater	Light blue
1,000 to 1,499	Green
500 to 999	Orange
Less than 500	Red